

CERTIFICATE of Conformity



Certificate No.: MK 69243792 0001

Test Report No.: 28212658 001

Certificate Holder: **Steca Elektronik GmbH**
Mammostraße 1
87700 Memmingen
Germany

Manufacturer: **Steca Elektronik GmbH**
Mammostraße 1
87700 Memmingen
Germany

Product: Photovoltaic (PV) grid-tie inverter

Identification: Type references:

- 1) StecaGrid 8000 3ph
- 2) StecaGrid 8000+ 3ph
- 3) StecaGrid 10000 3ph
- 4) StecaGrid 10000+ 3ph

DC Input		Nominal	AC Output	
Max inp.V	MPP/Operating		Range V; Max I	/phase 50Hz/
1) 845V	350-700V; max 27A	8kW	3x230V; 15A	
2) 845V	350-700V; max 27A	8kW	3x230V; 15A	
3) 845V	350-700V; max 32A	10kW	3x230V; 16A	
4) 845V	350-700V; max 32A	10kW	3x230V; 16A	

Phase: 3
Trademark: Steca

Tested according to: IEC 62109-1:2010
IEC 61727:2004

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date of Issue:

Budapest, 2013.03.13

